



In compliance with the Michigan Safe Drinking Water Act, Sylvan Township, Michigan is providing its customers with its annual Water Quality Report. This report covers the drinking water quality for Sylvan Township, for the calendar year 2022. This information is a snapshot of the quality of the water that we provided to you in 2022. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and State standards. For more information about your water, or the contents of this report contact Bob Halliwell at Infrastructure Alternatives Inc. @616-430-0663.

**WHAT IS THE SOURCE OF MY WATER?** Your water comes from 2 groundwater wells drilled into a source of water called a aquifer. After the water is pumped from the aquifer it goes through an iron removal process and then a reverse osmosis process. After treatment, the water is stored in a 500,000 gallon water tower, from their water flows through distribution mains to your house. The State has performed an assessment of our source water. Such an assessment was completed on all of the sources of drinking water across the country that provides water to 25 people or more. Each system's wells were given a rating based on how susceptible the source water is to contamination from identified sources. This will help communities understand the potential threats to their water supplies and prioritize needs for protecting the water from contamination. This does not mean that your water is or will become contaminated. The possible susceptibility rating ranges from low to very high. The rating for the wells is moderate for Sylvan Township.

**CONTAMINANTS AND THEIR PRESENCE IN WATER:** Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

**VULNERABILITY OF SUB POPULATIONS:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection, by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

**SOURCES OF DRINKING WATER:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture and residential uses.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production. It can also come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health

**IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OUR OPERATIONS?** The State and EPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2022. We are committed to providing you with safe, reliable, and healthy water. We are pleased to provide you with this information to



keep you fully informed about your water. We will be updating this report annually, and will also keep you informed of any problems that may occur throughout the year, as they happen. The Township board meetings are held on the first Tuesday of the month @ 7:00 p.m., 18027 Old US-12, Chelsea, Michigan.

The Water Quality Data Table lists all the drinking water contaminants that we detected during the 2022 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2022. The State allows us to monitor for certain contaminants less than one per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some is more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal(MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Action Level (AL):** The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **NA:** Not applicable **ND:** Not detectable to testing limit
- **ppb:** Parts per billion or micrograms per liter **ppm:** Parts per million or milligrams per liter **pci/l:** Picocuries per liter (a measure of radiation)

#### Water Quality Data Tables

Note: The presence of those contaminants in the water does not necessarily indicate that the water poses a health risk.

Inorganic Contaminants	Unit	MCL	MCLG	Level Detected	Range Detected	Sample Date	Violation	Typical source of contaminant
Barium	ppm	2	2	0.10	NA	9/28/20	No	Discharge of drilling wastes. Discharge of metal refineries. Erosion of natural deposits.
Calcium	ppm	NA	NA	24	NA	8/18/22	No	Erosion of natural deposits
Chloride	ppm	NA	NA	70	NA	8/18/22	No	Erosion of natural deposits
Hardness	ppm	NA	NA	83	NA	8/18/22	No	Erosion of natural deposits
Iron	ppm	NA	NA	ND	NA	8/18/22	No	Erosion of natural deposits
magnesium	ppm	NA	NA	5.6	NA	8/18/22	No	Erosion of natural deposits
Sodium	ppm	NA	NA	41	NA	8/18/22	No	Erosion of natural deposits
Sulfate	ppm	NA	NA	ND	NA	8/18/22	No	Erosion of natural deposits
<b>Disinfection Byproducts</b>	<b>Unit</b>	<b>MCL</b>	<b>MCLG</b>	<b>RAA</b>	<b>Range Detected</b>	<b>Sample Date</b>	<b>Violation</b>	<b>Typical source of contaminant</b>
Total Trihalomethanes (TTHM's)	ppb	80	NA	28.7	NA	8/18/21	No	Byproduct of drinking water disinfection.
Haloacetic acids(HAAS)	ppb	60	NA	5	NA	8/18/21	No	Byproduct of drinking water disinfection.
<b>Disinfection Residual</b>	<b>Unit</b>	<b>MRDL</b>	<b>MDRLG</b>	<b>Annual Average</b>	<b>Range Detected</b>	<b>Sample Date</b>	<b>Violation</b>	<b>Typical source of contaminant</b>
Chlorine	ppm	4.0	4	0.64	0.55 – .85	1/1/22 – 12/31/22	No	Water additive used to control microbes.
<b>Lead &amp; Copper</b>	<b>Unit</b>	<b>MCLG</b>	<b>Action Level</b>	<b>90% Percentile Value</b>	<b># of sites above action level and range</b>	<b>Sample Date</b>	<b>Exceeds</b>	<b>Typical source of contaminant</b>
Lead	ppb		15	1	0 0 ppb – 1 ppb	8/18/21-8/27/21	No	Lead service lines, corrosion of household plumbing including fittings and fixtures. Erosion of natural deposits.
Copper	ppm		1.3	0.9	0.0 0.3 – 0.9 ppm	8/18/21-8/27/21	No	Corrosion of household plumbing systems. Erosion of natural deposits.

**Lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sylvan Township is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**Copper:** Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's disease should consult their personal doctor.

H2O Compliance Services Inc. is Sylvan Townships Cross Control Program administrator. Questions, Testing should be directed to them at 989-723-5125 or [www.h2ocsi.com](http://www.h2ocsi.com)  
[orinfo@h2ocsi.com](mailto:orinfo@h2ocsi.com)